



CITY OF SEGUIN
Purchasing Department
PO Box 591, Seguin, Texas 78156-0591
Phone: (830) 401-2453 Fax: (830) 401-2414

October 29, 2012

ADDENDUM No. 1
City of Seguin Bid Package #47-2013-03
Steel Distribution Poles with CorroCote Ground Line Protection

Bid Due Date: November 6, 2012
 Bid Due Time: 2:30 P.M.
 Location: Seguin City Hall Council Chambers, Seguin, Texas

This addendum modifies, supplements, and is hereby made a part of the bid documents for City of Seguin Bid Package #47-2013-03.

1. Reference page 11, Section II, paragraph 7, "Pole Specifications". The following paragraph is hereby added:

The City of Seguin will not accept plastic caps on steel poles. Steel pole tops should be steel and must be welded or bolted on.

4. End this Addendum No. 1, October 29, 2012.

City of Seguin

Willa Hagemann

Willa Hagemann
 Assistant Director of Finance

Vendor shall acknowledge receipt of this Addendum by signing this Addendum and attaching it to his proposal.

Receipt is hereby acknowledged of the following addenda to the specifications to City of Seguin Bid #47-2013-03:

Addendum No. 1 Dated _____ Received _____

 Name and Title

 Date