



CITY OF SEGUIN
Purchasing Department
PO Box 591, Seguin, Texas 78156-0591
Phone: (830) 401-2451 Fax: (830) 401-2414

December 9, 2014

ADDENDUM NO. 2

CITY OF SEGUIN BID # TF-2015-07

Park West

This addendum modifies, supplements, and is hereby made a part of the bid document referenced above.

1. Attached Addendum No. 2, dated 9 December 2014, from Rialto Studios.

Twila Wood
Purchasing Manager
City of Seguin

Responses to additional Contractor Questions as of 9 December 2014:

- Q1. "Mock-up clarification." **See Item 01 below.**
- Q2. "Permissible to delay Subcontractor List 24 hours?" **The Subcontractor Information form may be submitted separately from the bid package. The deadline for submission of the Subcontractor Information form is 2:30 P.M., December 17, 2014 (CDST), format and delivery shall be identical to the bid package requirements. Deadline for Competitive Sealed Bid remains unchanged.**
- Q3. "Paint/plaster clarification." **All interior CMU and exterior Portland cement plaster wall surfaces are to be painted, refer to 09911 Interior and Exterior Painting and Item 02 below.**
- Q4. "Specifications for sign flood light fixtures." **On sheet E0.2 disregard the reference for flood lights at the park sign.**

ADDENDUM NO. 02 ITEMS:

Specifications

- Item 01:** Mock-ups: For CMU, plaster, and stone masonry provide mock-up sections of minimum four feet wide by final finished height for review. If approved, these sections can be part of the final wall. Follow individual Specifications sections for jointing and samples submittal. Stone samples for selection and approval purposes should be issued individually prior to mock-up.
- Item 02:** Division 9-09220-2.4-E-2: interpret "manufacturer's full range" as paint color.
- Item 03: (drawings clarification)** On Sheet Legends L2.1 thru L2.7 the reference for L1.0 should read L0.1.