



CITY OF SEGUIN
Purchasing Department
PO Box 591, Seguin, Texas 78156-0591
Phone: (830) 401-2451 Fax: (830) 401-2414

March 3, 2015

ADDENDUM NO. 1

CITY OF SEGUIN BID # TF-2015-21
Purchase of Transformers

This addendum modifies, supplements, and is hereby made a part of the bid document referenced above.

1. Electric System Material Standards, Section 4.0 Bushings and Terminals, Paragraph 4.2 revised to include “12 holes per spade” as follows:
 - 4.2 Low voltage bushings shall be wet process porcelain or epoxy. Terminals – 2 hole NEMA spade type, 9/16” holes, spaced on 1 ¾” centers, with ~~10~~ 12 holes per spade.

All bidders should acknowledge receipt of addenda on the first page of the Bid Form.

Twila Wood
Purchasing Manager
City of Seguin