



CITY OF SEGUIN
Purchasing Department
PO Box 591, Seguin, Texas 78156-0591
Phone: (830) 401-2451 Fax: (830) 401-2414

August 31, 2015

ADDENDUM NO. 2
CITY OF SEGUIN BID # TF-2015-40
Pavement Maintenance Project

This addendum modifies, supplements, and is hereby made a part of the bid document referenced above.

Questions received from a potential bidder followed by the City's response:

Q1: Do the quantities shown include a One Course Surface Treatment (chip seal) to be installed to the City Hall Parking Lot? If so, this application on parking lots has been unfavorable on some past projects due to the aggregate shelling off from twisting and turning of vehicle tires.

A1: Yes, the parking lot is included in the overall quantity.

Q2: Would the City consider a Value Engineering proposal to apply a sealer (paint it black) instead of a chip seal?

A2: Not at this time.

Q3: Are there staging areas available for storing equipment and materials?

A3: The entry roads to each of these neighborhoods should be long enough to stage material and equipment.

Q4: Which streets get resurfaced?

A4: All streets within each neighborhood get resurfaced, including the entry road. The City will make any necessary repairs to the damaged asphalt prior to the seal coating. Windwood at 104 Windwood Circle; Heritage South at 1207 Meadow Run.

Twila Wood
Purchasing Manager
City of Seguin