



ELEVATION-SECTION A-A

ELEVATION-SECTION B-B

NOTES:

1. CHAMFER ALL EXPOSED EDGES  $\frac{3}{4}$ ".
2. REINFORCING STEEL SHALL BE CUT OR FIELD-BENT AS REQUIRED TO CLEAR PIPE AND MANHOLE OPENING.
3. MANHOLE FRAME AND COVER SHALL BE IN ACCORDANCE WITH CITY OF SEGUIN STANDARD.
4. CONCRETE COVERAGE OF STEEL SHALL BE 2" MIN AT ALL SURFACES.
5. ANY MODIFICATION TO THIS STANDARD SHALL BE THE RESPONSIBILITY OF THE ENGINEER.



THE CITY OF  
**SEGUIN**

|                           |      |                   |                    |
|---------------------------|------|-------------------|--------------------|
| DATE ISSUED: JUNE 1, 2013 |      | TITLE             |                    |
| REV                       | DATE | BY                | 4 SIDED AREA INLET |
|                           |      |                   |                    |
|                           |      |                   |                    |
|                           |      |                   |                    |
|                           |      |                   |                    |
| SCALE: N.T.S.             |      | DRAWING No. STM-9 |                    |