



CONCRETE SIDEWALK @ UTILITY POWER POLE DETAIL

NOTE:

THIS DETAIL TO BE USED WHENEVER A POWER POLE ENCRACHES ON SIDEWALK. A MINIMUM UNOBSTRUCTED CLEARANCE OF 42" IS TO BE MAINTAINED AROUND THE POLE AT THE LOCATIONS.



THE CITY OF
SEGUIN

DATE ISSUED:	JUNE 1, 2013		
REV	DATE	BY	

TITLE	
CONCRETE SIDEWALK @ UTILITY POWER POLE	
SCALE:	DRAWING No.
N.T.S.	SW-3