



**NOTE:**  
 ADJUST SLOPE FROM 1/4"/FT MINIMUM TO THE SLOPE OF THE SIDE STREET.

**NOTES:**

1. MATERIALS AND CONSTRUCTION METHODS SHALL CONFORM TO THE CITY OF SEGUIN STANDARD SPECIFICATIONS.
2. CONCRETE FOR THE VALLEY GUTTER SHALL BE CLASS A CONCRETE.
3. MONOLITHIC CURB AND GUTTER SHALL BE MEASURED BY PLAN QUANTITY PER SQUARE FEET AND PAID AS VALLEY GUTTER.
4. THE UPSTREAM CURB MID POINT MUST BE AT OR LOWER THAN THE BEGINNING P.C. AND 0.5% MINIMUM HIGHER THAN THE OPPOSING MID POINT.
5. ALLOWABLE CONSTRUCTION JOINT AT THE CENTER LINE WHEN TRAFFIC FLOW MUST BE MAINTAINED, CONSTRUCTED AS A CONTROL JOINT.

CONCRETE VALLEY GUTTER SECTION



THE CITY OF  
**SEGUIN**

DATE ISSUED: JUNE 1, 2013		TITLE	
REV	DATE	BY	CONCRETE VALLEY GUTTER SECTION SHEET 2 OF 2
SCALE: N.T.S.		DRAWING No. RDWY-7.2	