



MATERIALS FOR THE FIRE HYDRANT ASSEMBLIES SHALL BE PAID FOR AS FOLLOWS:

MAIN LINE TEE – DUCTILE IRON FITTINGS BID ITEM

6" PIPE – 6" PIPE BID ITEM

FIRE HYDRANT, BURY AND CONCRETE BLOCKING – FIRE HYDRANT BID ITEM

FIRE HYDRANT ASSEMBLY (MUELLER OR CLOW ONLY)

NOTES:

1. CONTRACTOR SHALL INSTALL BLUE REFLECTOR CENTERED ON PROPOSED STREET @ EACH PROPOSED/EXISTING FIRE HYDRANT.
2. BACKFILL MATERIAL SHALL MEET ASTM C-33 CRUSHED STONE #57.



THE CITY OF
SEGUIN

DATE ISSUED: JUNE 1, 2013		TITLE	
REV	DATE	BY	FIRE HYDRANT ASSEMBLY (MUELLER OR CLOW ONLY)
SCALE: N.T.S.		DRAWING No. WTR-6	