



TYPICAL LIFT/GRINDER STATION GATE DETAILS

NOTES:

1. ALL FOOTING DESIGNS SHALL BE PER FENCE MANUFACTURER.
2. CONTRACTOR SHALL SUBMIT GATE DESIGN PRIOR TO CONSTRUCTION.
3. INCLUDE STABILIZING BAR ATTACHED TO ONE OF THE GATES.
4. 6' FENCE SHALL HAVE A MIN OF 3 STRANDS OF BARBWIRE AND 8' FENCE SHALL HAVE A MIN OF 1 STRAND OF BARBWIRE



THE CITY OF  
**SEGUIN**

DATE ISSUED:	JUNE 1, 2013	
REV	DATE	BY

TITLE	
TYPICAL LIFT/GRINDER STATION GATE DETAILS	
SCALE:	DRAWING No.
N.T.S.	WW-10