



LIFT STATION/GRINDER STATION FENCE DETAIL

NOTES:

1. ALL CONCRETE SHALL HAVE A MINIMUM STRENGTH OF 5,000 P.S.I.
2. ALL REINFORCEMENT SHALL BE A.S.T.M. 615 GRADE 60.
3. ALL EXPOSED SIDES SHALL HAVE ROCK-LIKE TEXTURE.
4. ALL GATES SHALL HAVE ADDITIONAL STEEL SUPPORTS ADJACENT TO CONCRETE COLUMNS OR AS REQUIRED BY MANUFACTURER.
5. CONTRACTOR SHALL USE FENCRETE AMERICA LTD. OF SAN ANTONIO, TX (210)492-7911 OR APPROVED EQUAL FOR ALL FENCING AND GATES.



THE CITY OF
SEGUIN

DATE ISSUED:	JUNE 1, 2013	
REV	DATE	BY

TITLE	
LIFT/GRINDER STATION FENCE DETAILS	
SCALE:	DRAWING No.
N.T.S.	WW-12