



## STANDARD VALVE INSTALLATION (CLOW, KENNEDY AND MUELLER ONLY)

**NOTES:**

1. VALVE BOX SHALL NOT CONTACT WATERMAIN OR VALVE. VALVE & VALVE BOX SHALL BE SUPPORTED BY CONCRETE BLOCKING.
2. VALVE STEM RISER TO BE WITHIN 3' OF SURFACE.
3. CONTRACTOR MAY CONSTRUCT CONCRETE ENCASEMENT AFTER STREET RECONSTRUCTION. ASPHALT SHALL BE SAW-CUT IN NEAT DIMENSIONS.
4. READY MIX OR LEANCRETE IS NOT ACCEPTABLE FOR ENCASEMENT.
5. ALL BACKFILL MATERIAL SHALL MEET ASTM C-33 CRUSHED STONE #57.



THE CITY OF  
**SEGUIN**

DATE ISSUED: JUNE 1, 2013		TITLE	
REV	DATE	BY	STANDARD VALVE INSTALLATION
SCALE: N.T.S.		DRAWING No. WTR-4	