



WATER MAIN OFFSET DETAIL

NOTES:

1. MATERIALS AND COATINGS TO BE ACCORDANCE WITH WATER MAIN STANDARD SPECIFICATIONS.
2. RESTRAIN EXISTING PIPE BEYOND SECTION AS REQUIRED TO PREVENT MOVEMENT.
3. DUCTILE IRON PIPE FOR WATER LINE CONSTRUCTION SHALL BE ANSI/AWWA-C-150/A21.50 PRESSURE CLASS 250 UNLESS OTHERWISE NOTED.
4. FITTINGS SHALL CONFORM TO ANSI/AWWA-C110/A21.10 OR ANSI/AWWA-C153/A21.53 AND ANSI/AWWA-C111/A21.11 STANDARDS.
5. ALL FITTINGS SHALL BE CEMENT LINED ACCORDING TO ANSI/AWWA-C104/A21.4.
6. FITTINGS SHALL BE DUCTILE IRON OR COMPACT DUCTILE IRON.
7. D.I. PIPE SHALL INCLUDE POLYETHYLENE WRAP AS DETAILED IN THE SPECIFICATIONS.



DATE ISSUED: JUNE 1, 2013		TITLE	
REV	DATE	BY	
SCALE: N.T.S.		DRAWING No. WTR-1	